



CITY OF WINTER PARK

401 Park Avenue South

Winter Park, Florida

32789-4386

August 21, 2008

Christopher G. Birchfield
VP of Business Development
No Burn SE, Inc.
PO Box 525
Minneola, FL 34755

Ken Kilbourne
PO Box 4132
Winter Park, FL
32793

Re: Approval of product under Florida Building Code Sec. 104.11 Alternate Materials for "No-Burn Plus" for Shoppes of Park Avenue, 200 N. Park Avenue; Permit # 08-2083

Dear Mr. Birchfield and Mr. Kilbourne:

Based the test reports and information you have presented and our evaluation of this fire retardant product to be applied to structural steel in the above referenced project, we have approved its use in accordance with the specified amount to be applied to achieve a one hour fire rating.

If I can assist you further please let me know.

Respectfully,

George J. Wiggins, CBO
Director of Building & Legislative Affairs
City of Winter Park