

FIRE RESISTIVE CLASS RATING (FRCR) REQUIREMENTS

FRCR 1

- Framing (all wooden components) treated with No-Burn® WOOD GARD or No-Burn® WOOD GARD Mh (1 coat)
- Interior walls and ceilings treated with No-Burn® PLUS or No-Burn® PLUS Mh (1 coat)
- Void Areas treated with No-Burn® WOOD GARD or No-Burn® WOOD GARD Mh (2 coats)
- High hazard areas treated with No-Burn® PLUS or No-Burn® PLUS Mh (2 coats)
- New construction

FRCR 1-A

- Framing treated with No-Burn® PLUS or No-Burn® PLUS Mh (1 coat)
- New Construction

FRCR 2

- Framing (all wooden components) treated with No-Burn® WOOD GARD or No-Burn® WOOD GARD Mh (1 coat)
- Void Areas treated with No-Burn® WOOD GARD or No-Burn® WOOD GARD Mh (2 coats)
- New Construction

FRCR 3

- Attic structure treated with No-Burn® WOOD GARD or No-Burn® WOOD GARD Mh (1 coat)
- Interior walls and ceilings treated with No-Burn® PLUS or No-Burn® PLUS Mh (1 coat)
- High hazard areas treated with No-Burn® PLUS or No-Burn® PLUS Mh (2 coats)
- Usually existing structure

FRCR 4

- Interior walls and ceilings treated with No-Burn® PLUS or No-Burn® PLUS Mh (1 coat)
- High hazard areas treated with No-Burn® PLUS or No-Burn® PLUS Mh (2 coats)
- Usually existing structure

FRCR 5

- Attic structure treated with No-Burn® WOOD GARD or No-Burn® WOOD GARD Mh (1 coat)
- Usually existing structure